

मुख्य अग्निशमन अधिकारी
OFFICE OF THE CHIEF FIRE OFFICER
अण्डमान तथा निकोबार द्वीप समूह
Andaman and Nicobar Islands

Clearance Number : **FS/FCC/2023/795**

Port Blair dated **21/02/2023**

FIRE CLEARANCE CERTIFICATE

This is to certify that the **ANANDA MARGA SCHOOL** situated at **ananda marga school, junglighat, plot no : 13/1 ,JUNGLIGHT ,PORT BLAIR** bearing Survey No. **13/1** has been inspected and there is "**NO OBJECTION**" from fire safety point of view. The First Aid Fire Fighting arrangements in the **School** are found satisfactory and reliable for a period of one (1) year from the date of issue of this FCC, subject to no change is effected in the existing fire fighting arrangements.

Note:- Conditions for the validity of Fire Clearance Certificate(FCC)

1. The school consists of RCC 02 Blocks with G+2 floors and one single Storey building for functioning of classes from Nursery to VIII. There is no approved building plan for the school.
2. Building stability and satisfactory electrical installation to be ascertained from concerned agency.
3. FCC shall stand null and void if there is any violation in existing firefighting arrangements.
4. FCC may not be treated in any case for regularization of unauthorized construction, if any or violation in building plan.
5. All fire safety arrangements provided therein shall be maintained in good working conditions at all time and all staff members shall be well acquainted to operate all fire safety equipments.
6. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
7. Trained firefighting staff should be available round the clock.

8. Any deviation with regard to construction etc. shall be verified by the concerned building sanctioning authority.
9. Means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
10. Occupant load in class room should not be more than 4 m² per student
11. Any flammable/combustible material for construction is prohibited.
12. The strength of students in second floor of block-I should be restricted to 20 students in the floor.
13. The number of students in assembly hall situated at second floor of block-II should not be more than 30 students at a time.
14. Cooking of food should be done at a safe place away from the school building.
15. Classes from Nursery to Class-I standard should be in ground floor of the building.
16. Exit route towards road from playground to outside road provided adjacent to the block-II should be used for evacuation during emergency.

Copy to:-

1. The Secretary, PBMC, P/Blair
2. The Director of Education, P/Blair



Inspector Fire Brigade (Port Blair)
Andaman and Nicobar Islands

To

BIKASH CHANDRA MAHATO
ananda marga school, junglighat, plot no : 13/1
JUNGLIGHAT
PORT BLAIR
SOUTH ANDAMAN - 744103